



**MIAMI-DADE COUNTY**  
**DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY**  
**AFFAIRS (PERA)**  
**BOARD AND CODE ADMINISTRATION DIVISION**  
**NOTICE OF ACCEPTANCE (NOA)**

**MIAMI-DADE COUNTY**  
**PRODUCT CONTROL SECTION**  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/pera/](http://www.miamidade.gov/pera/)

**GAF Material Corporation**  
**1361 Alps Road**  
**Wayne, NJ 07470**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION: Cobra® FasciaFlow™ PVC Premium Intake Ventilation**

**APPROVAL DOCUMENT:** Drawing No. **SS-CFF-01**, titled "Cobra FasciaFlow Vent", sheet 1 of 1, dated 08/16/2011, prepared by GAF Material Corporation, signed and sealed by Duc T. Nguyen, P.E., bearing the Miami-Dade County Product Control approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Section.

**MISSILE IMPACT RATING: Large and Small Missile Impact Resistant**

**LABELING:** Each piece shall bear a permanent label marked at not more than 4' o.c. with the manufacturer's name or logo, Walpole, MA and following statement: "Miami-Dade County Product Control Approved" and per FBC 1715.9.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA consists of this page 1 and evidence page E-1, as well as approval document mentioned above. The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



*[Signature]*  
06/04/2012

**NOA No. 11-0506.02**  
**Expiration Date: May 31, 2017**  
**Approval Date: May 31, 2012**  
**Page 1**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Drawing No. **SS-CFF-01**, titled "Cobra FasciaFlow Vent", sheet 1 of 1, dated 08/16/2011, prepared by GAF Material Corporation, signed and sealed by Duc T. Nguyen, P.E.

**B. TESTS**

	<b><u>Test Report No.</u></b>	<b><u>Standard</u></b>	<b><u>Date</u></b>	<b><u>Signature</u></b>
1.	GAF-262-02-02	FBC, TAS 111(B)	10/08/10	Duc T. Nguyen, P.E.
2.	GAF-262-02-03	ASTM D1761	10/14/10	Duc T. Nguyen, P.E.
3.	GAF-262-02-01	FBC, TAS 100(A)	10/06/10	Duc T. Nguyen, P.E.

**C. CALCULATIONS**

1. None.

**D. QUALITY ASSURANCE**

1. Miami-Dade Department of Permitting, Environment, and Regulatory Affairs (PERA)

**E. MATERIAL CERTIFICATIONS**

1. Notice of acceptance No. **08-0422.07** issued to Royal Mouldings Limited for their PVC Mouldings, approved on May 22, 2008 and expiring on April 3, 2013.


**F. STATEMENTS**

1. Statement letter of code conformance to 2010 FBC, issued by Construction Materials Technologies, dated 03/09/2012, signed and sealed by Duc T. Nguyen, P.E.
2. No financial interest letter issued by Construction Materials Technologies, dated 08/20/2011, signed by Duc T. Nguyen, P.E.
3. Private label agreement dated 10/19/11.




06/04/2012

Carlos M. Utrera, P.E.  
Product Control Examiner  
NOA No. 11-0506.02  
Expiration Date: May 31, 2017  
Approval Date: May 31, 2012



Note: Use #10 x 2 1/2" Corrosive Resistant Screws




Royal Moulding Ltd. Plastic  
NOA # 08-0422.07 in compliance  
with FBC 2612

*Dulynm*  
Doc T. KAVEN  
P.E. No: 65034  
8/23/2011

Approved as complying with the  
Florida Building Code  
Date 05/31/2012  
NOA# 11-0506.02  
Miami Dade Product Control  
By *[Signature]*

DESIGN PRESSURE: -285 psf  
VENTILATION: 9.0 sq.in. of Net  
Free Area per lin. ft.



www.gaf.com  
1361 Alps Rd.  
Wayne, NJ 07470  
(ph) (973) 872-4421

DETAIL NUMBER

SS-CFF-01

SHEET NUMBER

1 of 1

ISSUE/ REVISION DATE  
8-16-11

# Cobra FasciaFlow Vent